



BOROUGH OF HADDONFIELD

Camden County, New Jersey

March 26, 2019

2019-03

AN ORDINANCE TO AMEND THE CODE OF THE BOROUGH OF HADDONFIELD, IN THE COUNTY OF CAMDEN, STATE OF NEW JERSEY TO AMEND CODE CHAPTER 114 ENTITLED FIRE PREVENTION REGARDING SINGLE STATION BATTERY OPERATED SMOKE ALARMS

BE IT ORDAINED by the Board of Commissioners of the Borough of Haddonfield in the County of Camden, State of New Jersey as follows:

SECTION I

1. §114-8(B) Sale or rental of property certificate of compliance is hereby amended as follows:

§ 114-8 Responsibilities of Haddonfield Bureau of Fire Prevention.

B. Sale or rental of property certificate of compliance.

(1)(a) Any one- and two-family dwelling containing at least one residential dwelling unit must have at least one smoke ~~detector~~ **alarm**, in satisfactory working order, on each level of the building or the applicable NFPA standard at the time of the inspection. **All single station battery operated smoke alarms shall be of the ten-year sealed battery type, and listed by ANSI/UL 217 effective January 1, 2019.**

SECTION II

If any section, subsection, paragraph, sentence, clause or phrase of the Ordinance shall be declared invalid for any reason whatsoever, such decision shall not affect the remaining portions of this Ordinance which shall continue in full force and effect, as to this end the provisions of the Ordinance are hereby declared to be severable.

SECTION III

This ordinance shall take effect immediately upon passage and publication as required by law.

NOTE: Items in **BOLD** are to be added and items with a ~~strikethrough~~ are to be deleted.



BOROUGH OF HADDONFIELD

Camden County, New Jersey

March 26, 2019

First Reading – March 12, 2019
Second Reading – March 26, 2019

I HEREBY CERTIFY THAT THE FOREGOING IS A TRUE, ACCURATE, AND COMPLETE COPY OF THE ORDINANCE ADOPTED BY THE BOARD OF COMMISSIONER, BOROUGH OF HADDONFIELD, COUNTY OF CAMDEN, STATE OF NEW JERSEY, AT THEIR REGULARLY SCHEDULED MEETING ON MARCH 26, 2019.



Deanna Bennett, Borough Clerk